



Parametric study for the penetration of combined cycle technologies into Cyprus power system

Dr. Andreas Poullikkas
Electricity Authority of Cyprus




1. The electricity sector in Cyprus
2. Fuel share (world and Cyprus)
3. Optimisation algorithm
4. Parametric study (data)
5. Cost-benefit analysis - CO₂ emissions
6. Conclusions



Present Status

1. Small isolated island power system
2. Depend on fossil fuels
3. Installed capacity 988MWe
4. Generation 3.552 million kWh (in 2001)
5. Peak load 689MWe (in 2001) - **775 MWe in 2002**

Location of EAC power stations





Existing generation system

Steam turbine units (HFO)

1. Moni power station 6x30MWe
2. Dhekelia power station 6x60MWe
3. Vasilikos power station 2x130MWe

Gas turbine units (Diesel)

1. Moni power station 4x37,5MWe
2. Vasilikos power station 1x38MWe



Future plans

1. **1x120MWe steam turbine by 2005** (HFO)
2. **1x180MWe combined cycle by 2006** (diesel or natural gas)
3. **RES:**

Wind energy (in progress 6MWe wind park)

Photovoltaics (roof-top)

World and Cyprus fuel share for electricity generation




| Technology | World* | | | | | Cyprus | | | | |
|-------------|--------|-------|-------|-------|-------|--------|-------|-------|-------|-------|
| | 1975 | 1980 | 1990 | 2000 | 2010 | 1975 | 1980 | 1990 | 2000 | 2010 |
| | % | | | | | | | | | |
| Coal | 36,7 | 38,1 | 38,2 | 37,8 | 38,2 | 0,0 | 0,0 | 0,0 | 0,0 | 0,0 |
| Oil | 22,1 | 19,7 | 11,3 | 9,6 | 8,0 | 100,0 | 100,0 | 100,0 | 100,0 | 65,8 |
| Natural gas | 2,5 | 12,0 | 13,7 | 14,8 | 24,3 | 0,0 | 0,0 | 0,0 | 0,0 | 28,2 |
| Nuclear | 5,9 | 8,6 | 17,0 | 17,6 | 12,3 | 0,0 | 0,0 | 0,0 | 0,0 | 0,0 |
| Renewables | 23,0 | 21,6 | 19,8 | 20,2 | 17,2 | 0,0 | 0,0 | 0,0 | 0,0 | 6,0 |
| Total | 90,2 | 100,0 | 100,0 | 100,0 | 100,0 | 100,0 | 100,0 | 100,0 | 100,0 | 100,0 |

*IEA (International Energy Agency), World Energy Outlook, Paris 2000.


Cyprus fuel share for electricity generation



Year 2000



Year 2010





IPP technology selection algorithm*

1. Economic model

2. Evaluation of candidate power technologies:

Capital cost

Fuel consumption and cost

Operation and maintenance cost

Plant load factor

Life expectancy etc.

3. Least cost power generation configuration

*Poullikkas A., “A technology selection algorithm for independent power producers”, *The Electricity Journal*, 2001.

Optimisation algorithm

Cost function*

$$\text{least cost solution} = \min [c_k] = \min \left[\frac{C_o + \sum_{j=1}^n \frac{C_j}{(1+i)^j}}{P_o + \sum_{j=1}^n \frac{P_j}{(1+i)^j}} \right]_k$$

- c : electricity unit cost for candidate generation technology k in €/kWh
- C_o : production cost of the reference year in €
- C : production cost of year j in €
- P_o : electricity production of the reference year in kWh
- P : electricity production of year j in kWh
- i : discount rate in %

*Poullikkas A., “A technology selection algorithm for independent power producers”, *The Electricity Journal*, 2001.



Eligible conventional plants

1. HFO steam turbine (business as usual scenario)
2. Gasoil open cycle gas turbine
3. Natural gas (LNG) open cycle gas turbine



Combined cycle technology - variations

1. Fuel type
2. Capital cost
3. Efficiency



Combined cycle technology - advantages


1. High thermal efficiency - LOTHECO, HAT
2. Low emissions
3. Low capital costs
4. Short construction times
5. Less space requirements
6. Flexibility in plant size
7. Fast start-up

Technical and economic parameters of candidate technologies

| Option No | Technology | Fuel type | Capacity | Capital Cost | Efficiency | Fuel net calorific value | Fuel cost | | Fixed O&M | Variable O&M |
|-----------|------------------------|-------------|----------|--------------|------------|--------------------------|-----------|------|------------|--------------|
| | | | MWe | €/kW | % | GJ/t | €/t | €/GJ | €/kW-month | €/MWh |
| 1 | Boiler / steam turbine | HFO | 120 | 1258 | 37,26 | 41,3 | 125 | 3,03 | 1,4 | 1,50 |
| 2 | Gas turbine | Gasoil | 81 | 550 | 27,14 | 42,5 | 190 | 4,47 | 1,25 | 6,00 |
| 3 | Gas turbine | Natural gas | 81 | 532 | 28,38 | 45,0 | 141 | 3,13 | 0,83 | 4,00 |
| 4 | Combined cycle | Gasoil | 180 | 700-900 | 40-70 | 42,5 | 190 | 4,47 | 1,57 | 3,20 |
| 5 | Combined cycle | Natural gas | 180 | 700-900 | 40-70 | 45,0 | 141 | 3,13 | 1,25 | 2,50 |


Cost-benefit analysis

Conventional technologies




Cost-benefit analysis

Diesel combined cycle




Cost-benefit analysis

Natural gas combined cycle




Cost-benefit analysis

80% load factor



CO₂ emissions

CO₂ emissions environmental indicator for natural gas combined cycle



▲ Parametric study for combined cycle technologies

▲ Variations in fuel type, capital cost and efficiency

▲ Cost-benefit analysis:

Conventional technologies

least cost solution

HFO steam turbine plant

Gasoil combined cycle

least cost solution

? > 60%, capital cost 700€/kW - 900€/kW

Natural gas combined cycle

least cost technology

▲ Reduction of CO₂ emissions by -18% (year 2010)